



SAUTER BACnet PICS

SAUTER modu630-RT

BACnet Protocol Implementation Conformance Statement

D100481749 - 02

Note:

This statement corresponds to the ANSI/ASHRAE 135-2020 release. Changes are taking place constantly, without prior notification.

Trademarks:

ASHRAE, ASHRAE BACnet are registered trademarks of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE)

BACnet is a trademark of the American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE)

Other brand names or product names mentioned are trademarks and/or registered trademarks of the owners of the respective rights.

Legend:

This document contains tables with symbols and abbreviations for which the following legend applies:

☒	yes, supported	☐	no, not supported
-, n/a	not applicable	CC	Conformance Code
()	comments in parenthesis	R	Required Readable
(R)	Network Port specific	W	Required Readable and Writable
O	(Conditionally) Optional	OD	Dynamic object deletion
OC	Dynamic object creation	COV	Change of value
OOS	Out-Of-Service writeable	IR/AR	Intrinsic / Algorithmic change reporting
CMD	Object commandable		

Content

Content	4
I. BACnet Protocol Implementation Conformance Statement	5
I.1 SAUTER modulo 6 BACnet Device	5
I.1.1 BACnet Conformance Certificate (BCC):	5
I.1.2 Product Description	5
I.1.3 BACnet Standardized Device Profile (Annex L)	5
I.1.4 BACnet Interoperability Building Blocks (Annex K)	5
I.1.5 Segmentation Capability	7
I.1.6 Object Types	8
I.1.7 Data Link Layer Options	12
I.1.8 Device Address Binding	15
I.1.9 Networking Options	15
I.1.10 Character Sets	15

I. BACnet Protocol Implementation Conformance Statement

I.1 SAUTER modulo 6 BACnet Device

Date	
Vendor Name	Fr. Sauter AG (Vendor ID: 80)
Product Name	modulo 6 BACnet Router and SC-Hub
Product Model Number	SAUTER modu630-RT: EY6RT30F001
Applications Software Version	1.0.5 (CASE Engine Interface, Function Index)
Firmware Revision	1.1.0 (BACnet Firmware)
BACnet Protocol Revision	Version 1, Revision 26

I.1.1 BACnet Conformance Certificate (BCC):

BACnet Profile	B-RTR, B-BBMD, B-SCHUB
Date	Jan. 9 th , 2024
Test Report	VG 2022_1014559
BTL-Listing	BTL-31125
Firmware Version	1.0.1
Model	EY6RT30F001

I.1.2 Product Description

The modu630-RT BACnet Router and SC-Hub is a configurable BACnet Router belonging to the SAUTER modulo 6 product range of native BACnet devices. As a router, it enables routing between two different BACnet networks, for example one BACnet/IP network and a BACnet/SC network. The device also supports BACnet Broadcast Management as well as BACnet Foreign Device functionalities on a BACnet/IP network as well as the Hub functionality on a BACnet/SC network. The unit supports routing between two different physical interfaces (e. g. WAN, LAN) thanks to its two Ethernet interfaces, as well as within the same physical interface thanks to its onboard switch.

I.1.3 BACnet Standardized Device Profile (Annex L)

☒	B-RTR	BACnet Router
☒	B-BBMD	BACnet Broadcast Management Device
☒	B-SCHUB	BACnet Secure Connect Hub

I.1.4 BACnet Interoperability Building Blocks (Annex K)

Supports following BIBBs:

Data Sharing-	BIBB	A	B
Read Property-	DS-RP-	☐	☒
Read Property Multiple-	DS-RPM-	☐	☒
Write Property-	DS-WP-	☐	☒
Write Property Multiple-	DS-WPM-	☐	☒
Change Of Value Unsubscribed-	DS-COVU-	☐	☒
Read Range-	DS-RR-	☐	☒

Device Management-	BIBB	A	B
Dynamic Device Binding-	DM-DDB-	☒	☒
Dynamic Object Binding-	DM-DOB-	☐	☒
Device Communication Control-	DM-DCC-	☐	☒
Reinitialize Device-	DM-RD-	☐	☒
Backup and Restore-	DM-BR-	☐	☒
Restart-	DM-R-	☐	☒
List Manipulation-	DM-LM-	☐	☒
Time Synchronization-	DM-TS	☐	☒
UTC Time Synchronization-	DM-UTC-	☐	☒

Network Management-	BIBB	A	B
Router Configuration-	NM-RC-	☐	☒
BBMD Configuration-	NM-BBMD-	☐	☒
Foreign Device Registration-	NM-FDR-	☒	-
Secure Connect Hub-	NM-SCH-	-	☒

The table below consolidates all BIBBs required for B-RTR and B-SCHUB profile as of Annex L. Supplementary BIBBs are in *italics*.

Data Sharing	Alarm & Event Management	Scheduling	Trending	Device & Network Management
DS-RP-B DS-RPM-B DS-WP-B DS-WPM-B DS_COVU-B DS-RR-B				DM-DDB-A, -B DM-DOB-B DM-DCC-B DM-RD-B DM-BR-B DM-R-B DM-LM-B DM-TS-B DM-UTC-B NM-RC-B NM-BBMDC-B NM-FDR-A NM-SCH-B

I.1.5 Segmentation Capability

- ☒ Able to transmit segmented messages
- ☒ Able to receive segmented messages

Window Size: 4
Window Size: 4

I.1.6 Object Types

Standard and proprietary object types are supported and may be present in the device.

Note:

Present-Value and Reliability properties are writable when Out-Of-Service = True.

Standard and proprietary objects may support optional functionality (Overview):

Object Type	ID	OC	OD	CMD	OOS	COV	IR/AR
Device	8	☐	☐	-	-	-	-
File	10	☐	☐	-	-	-	-
NetworkPort	56	☐	☐	-	-	-	-

Some standard objects may have proprietary properties in addition (Clause 23). There are no specific property range restrictions except those within the system SAUTER modulo 6 and the range restrictions of the BACnet Standard. Supported standard and proprietary objects may support the following optional and proprietary properties and in addition to the standard conformance code some writable properties:

I.1.6.1 Device & Network Management

Device (DEV = 8)

Standard Property	CC	R	W	Range Restriction
Object-Identifier	R	☒		
Object-Name	R	☒		
Object-Type	R	☒		
System-Status	R	☒		
Vendor-Name	R	☒		
Vendor-Identifier	R	☒		
Model-Name	R	☒		
Firmware-Revision	R	☒		
Application-Software-Version	R	☒		
Location	O	☒	☒	(up to 64 characters)
Description	O	☒	☒	(up to 128 characters)
Protocol-Version	R	☒		
Protocol-Revision	R	☒		
Protocol-Services-Supported	R	☒		
Protocol-Object-Types-Supported	R	☒		
Object-List	R	☒		
Structured-Object-List	O	☒	☐	
Max-APDU-Length-Accepted	R	☒		
Segmentation-Supported	R	☒		
Max-Segments-Accepted	O	☒		
Local-Time	O	☒	☒	(time sync service)
Local-Date	O	☒	☒	(time sync service)
UTC-Offset	O	☒	☒	-1440..1440 (configurable)
Daylight-Savings-Status	O	☒	☐	(automatic DST)
APDU-Segment-Timeout	O	☒	☐	
APDU-Timeout	R	☒		
Number-Of-APDU-Retries	R	☒		
Device-Address-Binding	R	☒		
Database-Revision	R	☒		
Configuration-Files	O	☒	☐	
Last-Restore-Time	O	☒	☐	
Backup-Failure-Timeout	O	☒	☒	
Backup-Preparation-Time	O	☒	☐	
Restore-Preparation-Time	O	☒	☐	
Restore-Completion-Time	O	☒	☐	
Backup-And-Restore-State	O	☒	☐	
Active-COV-Subscriptions	O	☒	☐	
Last-Restart-Reason	O	☒		
Time-Of-Device-Restart	O	☒		
Restart-Notification-Recipients	O	☒		(up to 10 recipients)
Serial-Number	O	☒	☐	
Property-List	R	☒	☐	
Profile-Name	O	☒	☐	

Proprietary Property	ID	R	W	Property Datatype Range Restriction
Hardware-Revision	8208	☒	☐	
Production-Date	8278	☒	☐	
Sauter-Battery-OK-Indication	8380	☒	☐	
Sauter-Identification-Flag-Enable	8411	☒	☒	

File (FL = 10)

Standard Property	CC	R	W	Range Restriction
Object-Identifier	R	☒		
Object-Name	R	☒		
Object-Type	R	☒		
Description	O	☒	☐	
File-Type	R	☒		
File-Size	R	☒	☒	0 (delete)
Modification-Date	R	☒		
Archive	W	☒	☒	
Read-Only	R	☒		
File-Access-Method	R	☒		
Property-List	R	☒		
Profile-Name	O	☒	☐	

Network Port (NP = 56)

Depending on the value of Network_Type property, the object properties required change. Properties are splitted into Base properties which are independent of the Network_Type value, and a subset of properties related to the specific value of the Network_Type Property.

Base properties (present on any Network_Type value)

Standard Property	CC	R	W	Range Restriction
Object_Identifier	R	☒		
Object_Name	R	☒		
Object_Type	R	☒		
Description	O	☒	☒	Writable only when Protocol_Level = BACNET_APPLICATION
Status_Flags	R	☒		
Reliability	R	☒		
Out_Of_Service	R	☒	☒	
Network_Type	R	☒		
Protocol_Level	R	☒		
Reference_Port	O	☒	☐	
Changes_Pending	R	☒		
Command	O	☒	☒	
Current_Health	O	☒	☐	
Command_Validation_Result	O	☒	☐	
Property_List	R	☒		
Profile_Name	O	☒	☐	

Case 1: Network_Type == ETHERNET & Protocol_Level == PHYSICAL

Standard Property	CC	R	W	Range Restriction
MAC_Address	(R)	☒		
Link_Speed	O	☒	☐	
Network_Interface_Name	O	☒	☐	

(R): The properties that are required based on the Network_Type and Protocol_Level are identified in the sub-tables with a (R) conformance code.

Case 2: Network_Type == IPV4 & Protocol_Level == BACNET_APPLICATION

Standard Property	CC	R	W	Range Restriction
Network_Number	(R)	☒	☒	
Network_Number_Quality	(R)	☒		
APDU_Length	(R)	☒		
MAC_Address	(R)	☒		
BACnet_IP_Mode	(R)	☒	☒	
BACnet_IP_UDP_Port	(R)	☒		
BBMD_Broadcast_Distribution_Table	O	☒	☒	
BBMD_Accept_FD_Registrations	O	☒	☒	
BBMD_Foreign_Device_Table	O	☒	☐	
FD_BBMD_Address	O	☒	☒	
FD_Subscription_Lifetime	O	☒	☐	

(R): The properties that are required based on the Network_Type and Protocol_Level are identified in the sub-tables with a (R) conformance code.

Proprietary Property	ID	R	W	Property Datatype Range Restriction
Sauter_home_port	8422	☒	☐	

Case 3: Network_Type == IPV4 & Protocol_Level == PROTOCOL

Standard Property	CC	R	W	Range Restriction
IP_Address	(R)	☒	☐	
IP_Subnet_Mask	(R)	☒	☐	
IP_Default_Gateway	(R)	☒	☐	
IP_DNS_Server	(R)	☒	☐	
IP_DHCP_Enable	O	☒	☐	
IP_DHCP_Lease_Time	O	☒	☐	
IP_DHCP_Lease_Time_Remaining	O	☒	☐	
IP_DHCP_Server	O	☒	☐	

(R): The properties that are required based on the Network_Type and Protocol_Level are identified in the sub-tables with a (R) conformance code.

Case 4: Network_Type == SECURE_CONNECT & Protocol_Level == BACNET_APPLICATION

Standard Property	CC	R	W	Range Restriction
Network_Number	(R)	☒	☒	
Network_Number_Quality	(R)	☒		
APDU_Length	(R)	☒		
MAC_Address	(R)	☒		
Max_BVLC_Length_Accepted	(R)	☒		
Max_NPDU_Length_Accepted	(R)	☒		
SC_Primary_Hub_URI	(R)	☒	☒	
SC_Failover_Hub_URI	(R)	☒	☒	
SC_Minimum_Reconnect_Time	(R)	☒		
SC_Maximum_Reconnect_Time	(R)	☒		
SC_Connect_Wait_Timeout	(R)	☒		
SC_Disconnect_Wait_Timeout	(R)	☒		
SC_Heartbeat_Timeout	(R)	☒		
SC_Hub_Connector_State	(R)	☒		
Operational_Certificate_File	(R)	☒		
Issuer_Certificate_Files	(R)	☒		
Certificate_Signing_Request_File	(R)	☒		
SC_Primary_Hub_Connection_Status	O	☒	☐	
SC_Failover_Hub_Connection_Status	O	☒	☐	
SC_Hub_Function_Enable	O	☒	☐	
SC_Hub_Function_Accept_URIs	O	☒	☐	
SC_Hub_Function_Binding	O	☒	☐	
SC_Hub_Function_Connection_Status	O	☒	☐	
SC_Failed_Connection_Requests	O	☒	☐	

Proprietary Property	ID	R	W	Property Datatype Range Restriction
Sauter_home_port	8422	☒	☐	

BACnet Protocol Implementation Conformance Statement

I.1.7 Data Link Layer Options

- ☒ BACnet IP, (Annex J)
- ☒ BACnet IP, (Annex J) BACnet Broadcast Management Device (BBMD)
- ☐ BACnet IP, (Annex J) Network Address Translation (NAT Traversal)
- ☒ BACnet Secure Connect (Annex AB)
 - ☒ BACnet Secure Connect Node
 - If direct connections are supported:
 - Maximum number of simultaneous direct connections initiated: none
 - Maximum number of simultaneous direct connections accepted: none
 - ☒ BACnet Secure Connect Hub Function
 - Maximum number of simultaneous hub connections accepted: 30
 - ☐ HTTPS Proxy Support
 - List the types of HTTPS proxies supported: none
 - ☐ Additional cipher suites supported beyond those required for TLS V1.3
 - The additional cipher suites supported using the cipher suite names as of the TLS Cipher Suite Registry at IANA (See RFC 8446):
 - none
 - ☐ Additional Transport Layer Security versions other than V1.3 supported
 - The TLS versions other than V1.3 that are supported, including the supported cipher suites for the version beyond those required, using the cipher suite names as defined by the TLS version supported:
 - none
 - ☒ Generates private keys internally, and provides matching certificate signing requests.
 - ☒ DNS host name resolution supported (RFC 1123)
 - ☒ mDNS host name resolution supported (RFC 6762)

I.1.8 Device Address Binding

- ☐ Static device binding supported ¹

I.1.9 Networking Options

- ☒ Router, Clause 6
 - Routing configurations: BACnet/IP – BACnet/SC
- ☐ Annex H, BACnet Tunnelling Router over IP

I.1.10 Character Sets

Supports following character sets²:

- | | | |
|---|---|-------------------------------------|
| ☒ ISO 10646 (UTF-8) | ☐ IBM™/Microsoft™ DBCS | ☐ ISO 8859-1 |
| ☐ ISO 10646 (UCS-2) | ☐ ISO 10646 (UCS-4) | ☐ JIS 0208 |

Outgoing character strings are communicated according to the selected character set (Sauter-character-set).

Incoming character strings with character sets other than ISO 10646 (UTF-8) will be mapped to ISO 10646 (UTF-8) internally.

¹ This is currently necessary for two-way communication with MS/TP slaves and certain other devices.

² Indicating support for multiple character sets does not imply that they can all be supported simultaneously.



© Fr. Sauter AG
Im Surinam 55
CH-4058 Basel

Tel. +41 61 - 695 55 55
Fax +41 61 - 695 55 10
www.sauter-controls.com
info@sauter-controls.com

Printed in Switzerland
Document Revision: 02
Released: 16.06.2025